



## HUNTER WATER CORPORATION

### CERTIFICATE OF APPROVAL

#### WATER & SEWERAGE INFRASTRUCTURE APPROVED PRODUCTS REGISTER

Approval Number	2009-10-WS	Approval Date	15/12/2009
HWC Reference	HW2008-220/3/35	Approval Expiry Date	15/12/2014

Manufacturer	Poly Pipe Pty Ltd
Contact Name	Roy Kanjikkal
Contact Number	02 4959 1087
Product Description	Poly Pipe – PE100 Pressure Pipe Range DN 25-400 , PN12.5 (SDR13.6) / PN16 (SDR11)
Approved Usage	Service connections $\leq$ DN 63; low pressure sewerage applications $\leq$ DN 160; project approved trenchless installations; buried crossings (encased)

Australian Standard	AS/NZS 4130:2003
Standard Certification	SMKP21482, WMKA21482
WSAA Specification	WSA PS 207
WSAA Appraisal Report	PA0812
Other 3 <sup>rd</sup> Party Certification	ISO9001 - QEC24573

#### CONDITIONS OF APPROVAL

1. Hunter Water reserves the right to withdraw or modify this certificate at any time
2. Hunter Water shall be advised in writing of any changes to the design, materials of construction, installation procedure or any other attribute of this product in advance of the change occurring
3. Hunter Water shall be advised in writing if any third party certification is withdrawn
4. PE Pipe is not approved for general reticulation
5. Minimum pressure rating of PN12 for sewer pressure applications and PN16 for water supply and recycled water applications

**AUTHORISED BY:**  
Manager Asset Management

**PRODUCT REVIEWER:**  
Ian Hiles